

COMMONWEALTH OF VIRGINIA

Southside Virginia Training Center

January 2014

Date	Make up lbs	Make up %	Total all Steam lbs	Date
1	62292	15.80	394130	1
2	49205	12.11	406320	2
3	66907	14.76	453380	3
4	50147	12.35	405940	4
5	37968	12.59	301510	5
6	58268	14.26	408570	6
7	86590	18.63	464670	7
8	75703	16.83	449680	8
9	69672	17.33	402010	9
10	68389	17.01	402050	10
11	40659	13.39	303580	11
12	51221	14.99	341620	12
13	54278	16.94	320330	13
14	60467	17.16	352320	14
15	60359	17.04	354320	15
16	72946	18.30	398620	16
17	57685	16.14	357350	17
18	75112	18.65	402640	18
19	62225	17.08	364340	19
20	62867	18.33	342970	20
21	3557	0.84	422070	21
22	92238	20.72	445250	22
23	85916	18.81	456760	23
24	94521	20.53	460450	24
25	94870	21.90	433250	25
26	62667	15.65	400350	26
27	58043	15.76	368270	27
28	87290	19.02	458880	28
29	113013	24.84	455020	29
30	88273	19.52	452150	30
31	68489	16.29	420490	31
Av/TI	2071838	16.71	12399290	
Remarks				

COMMONWEALTH OF VIRGINIA

Southside Virginia Training Center

February, 2014

Date	Make up lbs	Make up %	Total all Steam lbs	Date
1	55270	16.60	332940	1
2	52879	19.38	272840	2
3	72987	19.53	373640	3
4	66882	17.15	389900	4
5	76269	19.66	388020	5
6	73137	18.08	404590	6
7	63708	15.63	407580	7
8	64558	16.21	398190	8
9	66673	16.79	397140	9
10	64549	14.86	434380	10
11	81709	17.97	454670	11
12	84583	18.48	457760	12
13	72663	16.52	439870	13
14	63666	17.15	371160	14
15	63458	15.48	410020	15
16	62858	16.37	383900	16
17	67190	16.69	402620	17
18	55020	16.43	334910	18
19	49897	17.20	290100	19
20	51005	17.80	286600	20
21	47506	16.38	290110	21
22	48281	15.98	302060	22
23	47623	17.51	271990	23
24	55286	16.60	332970	24
25	69655	15.39	452650	25
26	76611	19.67	389420	26
27	64224	16.37	392250	27
28	78302	18.45	424330	28
29		0.00		29
30		0.00		30
31		0.00		31
Av/TI	1796448	17.13	10486610	
Remarks				

COMMONWEALTH OF VIRGINIA

CENTRAL STATE HOSPITAL

MARCH,2014

Date	Make up lbs	Make up %	Total all Steam lbs	Date
1	57594	17.04	338060	1
2	45065	16.00	281710	2
3	69022	15.59	442740	3
4	94712	21.57	439170	4
5	63641	15.80	402770	5
6	66065	15.54	425060	6
7	52421	12.24	428420	7
8	52421	19.86	263910	8
9	52421	18.17	288460	9
10	46240	15.69	294770	10
11	38151	15.67	243480	11
12	38543	13.51	285350	12
13	58943	14.57	404450	13
14	47248	14.33	329730	14
15	47248	17.72	266620	15
16	47256	12.27	385020	16
17	71238	16.29	437240	17
18	65782	15.70	418910	18
19	54287	14.10	385140	19
20	47381	13.50	350910	20
21	10871	3.96	274580	21
22	58252	24.34	239370	22
23	58252	17.20	338770	23
24	47389	12.57	377050	24
25	57910	14.95	387240	25
26	60701	15.14	400960	26
27	54062	16.20	333740	27
28	40242	15.61	257870	28
29	37118	15.51	239270	29
30	43258	13.48	321020	30
31	47564	16.40	290090	31
Av/TI	1631297	15.43	10571880	
Remarks				

COMMONWEALTH OF VIRGINIA

CENTRAL STATE HOSPITAL

APRIL 2014

Date	Make up lbs	Make up %	Total all Steam lbs	Date
1	35544	13.74	258770	1
2	33237	14.24	233330	2
3	34545	14.67	235540	3
4	39193	20.23	193700	4
5	30996	13.74	225660	5
6	33653	13.18	255320	6
7	41825	15.96	262010	7
8	33861	14.70	230420	8
9	35677	14.52	245710	9
10	37518	17.57	213540	10
11	34703	18.19	190820	11
12	31487	17.09	184250	12
13	25906	14.82	174860	13
14	32995	18.21	181190	14
15	43158	17.61	245080	15
16	54312	18.57	292470	16
17	40967	13.89	294950	17
18	52271	18.06	289410	18
19	36277	14.12	256960	19
20	34503	13.36	258230	20
21	65407	34.77	230190	21
22	36069	16.83	188100	22
23	34794	15.87	214320	23
24	35577	17.14	219180	24
25	29921	15.96	207530	25
26	30746	16.19	187500	26
27	29630	12.16	189960	27
28	45199	19.08	243680	28
29	34028	15.15	236880	29
30	29805	13.41	222222	30
31		#VALUE!		31
Av/TI	1113804	16.23	6861782	

Remarks Makeup hi Mar 21th filled Boiler No4 with water after outage

COMMONWEALTH OF VIRGINIA

CENTRAL STATE HOSPITAL

May,2014

Date	Make up lbs	Make up %	Total all Steam lbs	Date
1	32754	17.14	191080	1
2	35411	18.03	196440	2
3	33095	18.43	179530	3
4	29030	16.64	174450	4
5	73096	34.45	212190	5
6	39842	20.87	190900	6
7	34878	19.69	177120	7
8	34636	21.29	162680	8
9	36535	23.76	153780	9
10	34345	21.79	157600	10
11	28630	18.37	155840	11
12	36402	22.48	161940	12
13	30679	20.25	151470	13
14	29572	18.66	158500	14
15	29405	18.13	162210	15
16	29238	16.52	176940	16
17	30463	17.26	176490	17
18	32645	17.74	184050	18
19	35194	17.94	196130	19
20	35702	20.93	170600	20
21	26548	16.98	156320	21
22	29005	18.92	153270	22
23	29163	18.24	159880	23
24	29871	18.96	157550	24
25	29880	19.55	152850	25
26	22499	15.18	148220	26
27	31596	21.98	143730	27
28	29463	19.66	149860	28
29	32295	18.33	176150	29
30	25340	14.61	173440	30
31	28155	17.22	163520	31
Av/TI	1015369	19.43	5224730	
Remarks	Make up hi on 05-05-14 filled Boilier 3 after outage			

COMMONWEALTH OF VIRGINIA

CENTRAL STATE HOSPITAL

JUNE 2014

Date	Make up lbs	Make up %	Total all Steam lbs	Date
1	24690	15.30	161380	1
2	29380	17.76	165430	2
3	30063	19.44	154630	3
4	28888	19.26	149960	4
5	30388	19.56	155370	5
6	32712	21.46	152410	6
7	28072	19.52	143780	7
8	27631	19.57	141220	8
9	31546	21.11	149470	9
10	29963	20.51	146090	10
11	27906	20.00	139510	11
12	31787	20.29	156650	12
13	30821	20.54	150060	13
14	29638	20.38	145420	14
15	28755	20.15	142680	15
16	31354	21.38	146660	16
17	29255	20.44	143110	17
18	27889	20.39	136750	18
19	29705	21.07	140970	19
20	24474	16.68	146750	20
21	29638	21.53	137660	21
22	28988	20.32	142630	22
23	100	0.07	147840	23
24	28980	19.77	146580	24
25	27772	19.52	142310	25
26	28297	19.59	144470	26
27	25515	17.97	141970	27
28	27631	20.35	135780	28
29	25073	18.37	136480	29
30	23291	17.32	134500	30
31		#VALUE!		31
Av/TI	830201	18.96	4378520	
Remarks	06-23-14 Meter for Makeup malfunctioned			

COMMONWEALTH OF VIRGINIA

CENTRAL STATE HOSPITAL

July 2014

Date	Make up lbs	Make up %	Total all Steam lbs	Date
1	26339	19.27	136680	1
2	26464	19.94	132740	2
3	22324	17.42	128170	3
4	27239	21.51	126620	4
5	24998	19.00	131580	5
6	26706	20.73	128840	6
7	25973	19.89	130560	7
8	30371	23.46	129460	8
9	25731	19.75	130300	9
10	26156	19.35	135140	10
11	26681	19.52	136690	11
12	27297	21.51	126910	12
13	25023	20.28	123380	13
14	24024	18.16	132320	14
15	31262	22.92	136410	15
16	27122	19.63	138140	16
17	20550	16.12	127490	17
18	27489	20.23	135900	18
19	24315	18.80	129330	19
20	24807	19.57	126790	20
21	21242	15.12	140460	21
22	25756	19.46	132350	22
23	25756	20.03	128580	23
24	25157	18.10	139000	24
25	25307	18.00	140600	25
26	25990	19.83	131090	26
27	26806	20.36	131690	27
28	27706	19.74	140370	28
29	29047	21.08	137800	29
30	28064	20.15	139270	30
31	28072	20.75	135270	31
Av/TI	809776	19.66	4119930	
Remarks				

COMMONWEALTH OF VIRGINIA

CENTRAL STATE HOSPITAL

August, 2014

Date	Make up lbs	Make up %	Total all Steam lbs	Date
1	33020	21.95	150420	1
2	35269	23.80	148160	2
3	36760	24.88	147740	3
4	42608	27.77	153430	4
5	37768	26.14	144470	5
6	39168	27.34	143260	6
7	31829	22.12	143870	7
8	37393	25.84	144720	8
9	36161	25.45	142060	9
10	31979	23.00	139040	10
11	33495	22.93	146100	11
12	31687	22.65	139910	12
13	29655	21.33	139000	13
14	20867	14.68	142150	14
15	20883	14.72	141840	15
16	20875	15.80	132120	16
17	20858	15.70	132820	17
18	27972	20.48	136550	18
19	34203	24.71	138420	19
20	27381	20.55	133210	20
21	28514	21.91	130120	21
22	23790	17.80	133650	22
23	30021	22.89	131180	23
24	29838	21.99	135690	24
25	24532	16.60	147810	25
26	42341	28.82	146940	26
27	29372	20.81	141170	27
28	26140	19.19	136240	28
29	26923	19.31	139450	29
30	28772	22.09	130270	30
31	27606	21.49	128480	31
Av/TI	947679	21.83	4340290	
Remarks				

COMMONWEALTH OF VIRGINIA

CENTRAL STATE HOSPITAL

September, 2014

Date	Make up lbs	Make up %	Total all Steam lbs	Date
1	26256	20.51	128040	1
2	35994	26.30	136840	2
3	28564	20.26	140990	3
4	29380	20.59	142700	4
5	29163	20.38	143100	5
6	28347	20.93	135410	6
7	29821	20.61	144690	7
8	34003	21.28	159790	8
9	28155	18.51	152130	9
10	28247	19.24	146820	10
11	53179	34.08	156020	11
12	29263	18.74	156180	12
13	24407	15.36	158890	13
14	24598	15.04	163510	14
15	20384	13.94	146230	15
16	26739	19.25	138870	16
17	23499	16.34	143780	17
18	26190	17.58	148990	18
19	21891	14.13	154970	19
20	24007	17.41	137900	20
21	25157	18.62	135110	21
22	23049	15.73	146500	22
23	31213	19.75	158010	23
24	24823	15.83	156820	24
25	25182	16.13	156110	25
26	27831	18.21	152850	26
27	25706	17.55	146440	27
28	25715	17.99	142960	28
29	20075	12.54	160060	29
30	27489	17.20	159790	30
31		#VALUE!		31
Av/TI	828327	18.61	4450500	

Remarks '09-11-14 Make up hi filled Boiler No 1 annual inspection

COMMONWEALTH OF VIRGINIA

CENTRAL STATE HOSPITAL

October 2014

Date	Make up lbs	Make up %	Total all Steam lbs	Date
1	19859	12.32	161250	1
2	29338	19.31	151900	2
3	26414	17.27	152930	3
4	24757	14.40	171970	4
5	27947	14.94	187040	5
6	31362	15.98	196270	6
7	23107	11.00	210100	7
8	24215	13.69	176860	8
9	28164	15.96	176440	9
10	24890	14.24	174780	10
11	28047	14.64	191540	11
12	25132	13.72	183140	12
13	22808	14.08	162000	13
14	58527	34.49	169680	14
15	33262	17.19	193530	15
16	28247	14.71	192010	16
17	27822	15.79	176210	17
18	27031	15.17	178220	18
19	31021	14.98	207110	19
20	38576	17.30	222970	20
21	31487	15.16	207760	21
22	34678	14.45	239960	22
23	43341	18.68	232010	23
24	35286	14.89	236900	24
25	35786	16.85	212340	25
26	34320	15.50	221480	26
27	44940	19.27	233260	27
28	41758	19.75	211470	28
29	52704	23.94	220160	29
30	47173	19.06	247460	30
31	57285	21.69	264070	31
Av/TI	1039284	16.86	6162820	
Remarks '10-14-14 makeup hi due to filled boiler no2 after inspection				

COMMONWEALTH OF VIRGINIA

CENTRAL STATE HOSPITAL

November 2014

Date	Make up lbs	Make up %	Total all Steam lbs	Date
1	60101	19.39	310030	1
2	55128	18.11	304430	2
3	57752	20.92	276030	3
4	53254	21.72	245230	4
5	48989	20.56	238310	5
6	50521	19.32	261510	6
7	56461	19.91	283640	7
8	53337	19.05	279950	8
9	49055	17.55	279590	9
10	58285	21.74	268160	10
11	39826	18.25	218220	11
12	57119	23.74	240600	12
13	64882	20.45	317260	13
14	57560	16.41	350660	14
15	63525	18.95	335190	15
16	57894	18.89	306470	16
17	75536	24.68	306100	17
18	68831	17.40	395580	18
19	76419	19.44	393090	19
20	66473	19.04	349120	20
21	75262	19.50	385900	21
22	65899	18.83	349950	22
23	55003	19.03	289000	23
24	54337	22.65	239870	24
25	60434	21.53	280760	25
26	68239	20.08	339900	26
27	59143	17.31	341760	27
28	65166	17.99	362220	28
29	65224	19.94	327070	29
30	50272	18.76	267930	30
31		#VALUE!		31
Av/TI	1789925	19.58	9143530	
Remarks				

COMMONWEALTH OF VIRGINIA

CENTRAL STATE HOSPITAL December, 2014

Date	Make up lbs	Make up %	Total all Steam lbs	Date
1	65415	25.09	260750	1
2	55111	15.14	363940	2
3	66090	21.88	302090	3
4	67032	21.18	316470	4
5	68081	21.97	309920	5
6	56969	19.02	299450	6
7	62200	18.19	341950	7
8	83600	22.63	369470	8
9	78444	22.26	352350	9
10	79535	23.27	341824	10
11	82709	23.16	357190	11
12	67481	20.36	331500	12
13	65074	19.63	331500	13
14	60942	18.38	331500	14
15	78635	23.72	331500	15
16	65074	19.25	338020	16
17	69206	21.00	329550	17
18	69431	19.88	349330	18
19	80526	22.14	363650	19
20	63666	17.89	355910	20
21	61750	17.85	345920	21
22	78552	20.94	375080	22
23	66240	19.18	345440	23
24	61825	21.92	282070	24
25	116395	35.06	331990	25
26	74095	21.39	346440	26
27	55486	18.52	299630	27
28	55469	19.28	287670	28
29	85308	23.12	368950	29
30	73529	18.60	395240	30
31	82184	20.54	400170	31
Av/TI	2196055	21.00	10456464	
Remarks				