

Southside Virginia Training Center

Heating Plant Month Operations Report

10/31/2012
 11:59 PM
 Monthly Report

Description

	Plant				Units
Heating Degree Days	306.90				hdd
Total Plant Steam Flow	6,330.94				klbs
Steam Flow Per Heating Degree Day	20.6				klbs/hdd
Total Condensate Return Water Flow	214.5				klbs
Total Plant Gas Flow	7,556.16				kscf
Total Plant Gas Cost	\$52,152.75				\$
Total Plant Oil Flow	0.0				gals
Total Plant Oil Cost	\$0.00				\$
Total Plant Fuel Cost	\$52,152.75				\$
Fuel Cost Per Heating Degree Day	\$169.93				\$/hdd
Plant Average Steam Cost Per Degree Day	\$0.03				\$/klbs
Total Plant Efficiency By I/O	82.1				%
Condensate Transfer Pump #1 Run Time	295.6				hrs
Condensate Transfer Pump #2 Run Time	167.1				hrs
Condensate Transfer Pump #3 Run Time	280.6				hrs
Boiler Feed Pump #1 Run Time	173.1				hrs
Boiler Feed Pump #2 Run Time	201.6				hrs
Boiler Feed Pump #3 Run Time	133.5				hrs
Boiler Feed Pump #4 Run Time	239.1				hrs
Fuel Oil Pump #1 Run Time	0.0				hrs
Fuel Oil Pump #2 Run Time	0.0				hrs
	Boiler 1	Boiler 2	Boiler 3	Boiler 4	Units
Run Time	169.4	2.0	253.5	330.3	hrs
Steam Flow	1510.51	3.50	2088.11	2728.82	klbs
Gas Flow	1796.61	15.37	2453.66	3290.52	kscf
Natural Gas Cost	\$12,400.23	\$106.08	\$16,935.15	\$22,711.29	\$
Oil Flow	0.0	0.0	0.0	0.0	gals
Oil Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Total Fuel Cost	\$12,400.23	\$106.08	\$16,935.15	\$22,711.29	\$
Average Steam Cost	\$8.21	\$30.31	\$8.11	\$8.32	\$/klbs
Efficiency By Losses	83.2	72.0	83.1	82.3	%
Efficiency By I/O	82.3	22.3	83.3	81.2	%